



2024 Consumer Confidence Report
St. John Water District 3 (Laplace)
Public Water Supply ID: LA1095007

We are pleased to present to you the Annual Water Quality Report for the year 2024. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source(s) are listed below:

| Source Name | Source Type |
|-----------------|--------------|
| Ruddock Well #1 | Ground Water |
| Ruddock Well #2 | Ground Water |

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substance resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial Contaminants – such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock, operations and wildlife.
- Inorganic Contaminants – such as salts and metals which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and Herbicides – which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive Contaminants – which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We are pleased to report that our drinking water is safe and meets Federal and State requirements. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply want to learn more about your drinking water, please contact Jaclyn Hotard at 985-652-9569 Ext 1244.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2024. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we’ve provided the following definitions:

- Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter (ug/l)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.
- Treatment Technique (TT)** - an enforceable procedure or level of technological performance which public water systems must follow to ensure control of a contaminant.
- Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum contaminant level (MCL)** – the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.
- Maximum contaminant level goal (MCLG)** – the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG’s allow for a margin of safety.
- Maximum residual disinfectant level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum residual disinfectant level goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Level 1 assessment** – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system
- Level 2 assessment** – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Our water system grade is a “B”. Our water system report card can be found at “<https://ldh.la.gov/bureau-of-engineering-services/watergrade/>”

Our water system tested a minimum of 30 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. During the monitoring period covered by this report, we had the following noted detections for microbiological contaminants:

| Disinfectant | Date | HighestRAA | Unit | Range | MRDL | MRDLG | Typical Source |
|--------------|------|------------|------|-------------|------|-------|--|
| CHLORAMINE | 2024 | 1.8 | ppm | 0.13 – 3.04 | 4 | 4 | Water additive used to control microbes. |

In the table below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers to the latest year of chemical sampling results. The State of Louisiana regularly monitors source water per State and Federal Regulations. Treated water samples are monitored to further evaluate compliance.

| Source Water Regulated Contaminants | Collection Date | Highest Value | Range | Unit | MCL | MCLG | Typical Source |
|-------------------------------------|-----------------|---------------|---------|------|-----|------|---|
| FLUORIDE | 11/13/2024 | 0.8 | 0.8 | ppm | 4 | 4 | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| NITRATE-NITRITE | 11/13/2024 | 0.1 | 0 – 0.1 | ppm | 10 | 10 | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |

| Source Water Radiological Contaminants | Collection Date | Highest Value | Range | Unit | MCL | MCLG | Typical Source |
|--|-----------------|---------------|--------------|-------|-----|------|-----------------------------|
| COMBINED RADIUM (-226 & - 228) | 11/13/2024 | 1.65 | 0.514 – 1.65 | pCi/l | 5 | 0 | Erosion of natural deposits |
| RADIUM – 226 | 11/13/2024 | 0.844 | 0 – 0.514 | pCi/l | 5 | 0 | Erosion of natural deposits |
| RADIUM – 228 | 11/13/2024 | 0.844 | 0 – 1.65 | pCi/l | 5 | 0 | Erosion of natural deposits |

| Lead and Copper | Date | 90 TH Percentile | Range | Unit | AL | Sites Over AL | Typical Source |
|-----------------|-------------|-----------------------------|-------|------|-----|---------------|--|
| COPPER, FREE | 2020 – 2023 | 0 | 0 | ppm | 1.3 | 0 | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood perservatives |
| LEAD | 2020 – 2023 | 1 | 0 – 3 | ppb | 15 | 0 | Corrosion of household plumbing systems; Erosion of natural deposits; |

| Disinfection Byproducts | Sample Point | Period | Highest LRAA | Range | Unit | MCL | MCLG | Typical Source |
|--------------------------------|-------------------------------|-------------|--------------|------------|------|-----|------|---|
| TOTAL HALOACETIC ACIDS (HAA5)_ | 1300 EAST AIRLINE AT COLONIAL | 2023 – 2024 | 1 | 0 – 0.76 | ppb | 60 | 0 | By-product of drinking water disinfection |
| TOTAL HALOACETIC ACIDS (HAA5) | 180 GROVE PARK | 2023 – 2024 | 1 | 0 – 0.72 | ppb | 60 | 0 | By-product of drinking water disinfection |
| TOTAL HALOACETIC ACIDS (HAA5) | 2247 PINE VALLEY | 2023 – 2024 | 1 | 0 – 0.9 | ppb | 60 | 0 | By-product of drinking water disinfection |
| TOTAL HALOACETIC ACIDS (HAA5) | 434 ELM STREET | 2023 – 2024 | 1 | 0.42 – 0.8 | ppb | 60 | 0 | By-product of drinking water disinfection |
| TOTAL HALOACETIC ACIDS (HAA5) | 731 BELLE POINTE BLVD | 2023 – 2024 | 1 | 0 – 0.78 | ppb | 60 | 0 | By-product of drinking water disinfection |
| TTHM | 1300 EAST AIRLINE AT COLONIAL | 2023 – 2024 | 5 | 4.6 – 5 | ppb | 80 | 0 | By-product of drinking water chlorination |
| TTHM | 180 GROVE PARK | 2023 – 2024 | 5 | 4.7 – 5.1 | ppb | 80 | 0 | By-product of drinking water chlorination |
| TTHM | 2247 PINE VALLEY | 2023 – 2024 | 5 | 4.4 – 5.3 | ppb | 80 | 0 | By-product of drinking water chlorination |
| TTHM | 434 ELM STREET | 2023 – 2024 | 6 | 4.3 – 4.7 | ppb | 80 | 0 | By-product of drinking water chlorination |
| TTHM | 731 BELLE POINTE BLVD | 2023 – 2024 | 5 | 4.8 – 4.9 | ppb | 80 | 0 | By-product of drinking water chlorination |

| Source Secondary Contaminants | Collection Date | Highest Value | Range | Unit | SMCL |
|-------------------------------|-----------------|---------------|-------------|------|------|
| ALUMINUM | 11/13/2024 | 0.01 | 0 – 0.01 | mg/L | 0.2 |
| CHLORIDE | 11/13/2024 | 244 | 112 - 244 | mg/L | 250 |
| HARDNESS, TOTAL (As CaCO3) | 11/13/2024 | 7.9 | 5.6 – 7.9 | mg/L | 0 |
| IRON | 11/13/2024 | 0.01 | 0 – 0.01 | mg/L | 0.3 |
| MANGANESE | 11/13/2024 | 0.03 | 0.01 – 0.03 | mg/L | 0.05 |
| PH | 11/13/2024 | 8.7 | 8.51 – 8.7 | su | 8.5 |
| POTASSIUM | 11/13/2024 | 1.4 | 1 – 1.4 | mg/L | 0 |
| SODIUM | 11/13/2024 | 327 | 258 – 327 | mg/L | 0 |
| SULFATE | 11/13/2024 | 6 | 3 – 6 | mg/L | 250 |

| Treated Secondary Contaminants | Collection Date | Highest Value | Range | Unit | SMCL |
|--------------------------------|-----------------|---------------|-------|------|------|
| IRON | 12/18/2024 | 0.02 | 0.02 | mg/L | 0.3 |

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. St. John Water District 3 is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact St. John Water District 3 and Jaclyn Hotard BUS Phone: 985-652-9569 Ext 1244. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

The Lead Service line inventory can be reviewed at the following website <https://www.sjbparish.gov/Departments/Utilities/Lead-Service-Line-Inventory>.

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.

We at St. John Water District 3 work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of our community, our way of life, and our children’s future. Please call our office if you have questions.