

JUNE 9, 2025

REGALA PARK FLAG FOOTBALL FIELD
A/E PROJECT NO. 24-1130-0049



ST. JOHN THE BAPTIST PARISH
OWNER



MEYER ENGINEERS, LTD.
ENGINEER AND ARCHITECT

NOTICE TO BIDDERS:

This Addendum shall be considered part of the Contract Documents for the same above-mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Acknowledge receipt of the addendum by inserting its number on the Bid Form of the Bid Documents. Failure to do so will cause the bid response to be rejected.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

AD2.1 Contractor Questions and Answers:

Q: Will builder's risk and OCP insurance be required?

A: **Yes, see specs for insurance requirements.**

Q: Will the site require security fencing enclosure?

A: **Not required, but Contractor is responsible for equipment and site safety.**

Q: Will the stone subbase and base be allowed with ACT turf? If so, will a detail of the drainage system be provided to show intent?

A: **Concrete subbase required to keep consistency across campus.**

Q: Will any strippings be allowed to stay onsite or will all materials need to be removed?

A: **All strippings to remain on site. Either spread to grade out field, or piles to be moved to Owner stockpile at Northeast Corner of property.**

Q: Will any conformance surveys need to be provided?

A: **Final grades to be provided by contractor, grades do not need to be stamped by a licensed surveyor.**

AD2.2 Approved Equals: Listed below are manufacturers who are recognized as capable of producing materials, manufactured items, and articles of equipment equal to those specified. Equipment will be considered acceptable providing the equipment meets, or exceeds specification requirements, has the capacity and performance requirements, fits the space available to the satisfaction of the Engineer, conforms in every respect with the applicable regulatory agencies. Contractor shall submit for approval large scale drawings of proposed layouts and arrangements of substitute equipment when requested.

The listed prior approvals are not given with respect to any specific model, series, catalog number, etc. Suppliers are cautioned that before their equipment is actually approved, it will be incumbent upon them to demonstrate to the Engineer that it is in fact equal to the requirements specified and conforms fully to all specification requirements.

MATERIAL/EQUIPMENT

Artificial Turf

MANUFACTURER

Sprinturf

* * *