

AUGUST 7, 2025

REGALA PARK FLAG FOOTBALL FIELD
A/E PROJECT NO. 24-1130-0049



ST. JOHN THE BAPTIST PARISH
OWNER



MEYER ENGINEERS, LTD.
ENGINEER AND ARCHITECT

NOTICE TO BIDDERS:

This Addendum shall be considered part of the Contract Documents for the same above-mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Acknowledge receipt of the addendum by inserting its number on the Bid Form of the Bid Documents. Failure to do so will cause the bid response to be rejected.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

AD2.1 Contractor Questions and Answers:

- Q: Would you be able to let us know the thickness of the sidewalk and of the concrete pad under the field?
- A: Sidewalk shall be 5" thick. See Spec Section 02542 for structural base requirements.

* * *