




CONTRACT DOCUMENTS FOR
ST. JOHN THE BAPTIST PARISH

07/23/2026 WOODLAND WASTEWATER TREATMENT PLANT
DEMOLITION PROJECT

BID NO.: 2026.16

ADDENDUM NO. 3

DATE ISSUED: JULY 23, 2026

BID SUBMITTAL DEADLINE: AUGUST 5, 2026 at 9:45AM

BID LOCATION: 1811 W. Airline Highway, LaPlace, LA 70068

This addendum shall be considered part of the Contract Documents for the same above-mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from the original Contract Documents, this Addendum shall govern and take precedent.

Acknowledge receipt of the addendum by inserting its number and date on the Bid Form of the Bid Documents. Failure to do so will cause the bid response to be rejected.

The following items are issued to add to, modify, and clarify the Contract Documents. These items shall have full force and effect as in the Contract Documents, and the cost involved shall be included in the bid prices. It will be construed that each Bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

This Addendum No. 3 consists of 3 pages including the title sheet and all attachments.

AD1.1 The Bid date has been revised to submit bids by 9:45 A.M. on Wednesday, August 5, 2026 to be opened at 10:00 A.M.

AD1.2 Revising a previous response to a question in Add No. 2 – the weight limit on the bridge accessing the WWTP is 15-tons.

AD1.3 Bidder Questions (Q&A)

Q1: Can spec'd crushed concrete be used if it is #57 sized stone?

A1: No. Demolished concrete may not be used as backfill.

Q2: Are you forced to use River Birch LLC, or can you find a cheaper legal alternative?

A2: The Contractor may utilize any disposal or recycling facility that is properly permitted and legally authorized to accept the waste materials generated by the Project. The Contractor shall be responsible for complying with all applicable federal, state, and local laws and regulations governing transportation, recycling, and disposal of such materials.

Q3: Will you provide a list via a addendum of the painted items to be saved?

A3: No, the Owner will mark items to be salvaged after the bid

Q4: Will you draw down the clarification tanks and dispose of the water into the system?

A4: It will be the Contractor's responsibility to dispose of water in the tank to the pump station on site

Q5: Will a Louisiana Demolition/house moving/wrecking license be sufficient or equal to and acceptable?

A5: A Municipal and Public Works License is required for this project

Q6: Concrete crushing? Is this allowed on site, and either gift it to the parish or water department?

A6: Yes provided the Contractor monitors noise and dust control.

Q7: When will everything to be saved get marked, and will pictures be provided?

A7: The Owner will mark items to be salvaged after the bid

Q8: Can the clarification tanks be drained back into the system for disposal?

A8: Yes, it will be the Contractor's responsibility to dispose of water in the clarification tanks to the pump station on site

Q9: Any other pits /voids that hold water, can this be pumped back into the system?

A9: All water remaining in the structures to be demolished can be disposed of in the pump station on site.

Q10: How far away is the other WWTP?

A10: River Birch LLC is approximately 30 miles away from Woodland WWTP